

*Hailey Fire Dept.  
617 S. Third Street  
P.O. Box 1192  
Hailey, Idaho 83333*



*Capt. Michael Baledge  
Fire Marshal  
Office: 208-788-3147  
Fax: 208-788-0279  
E-mail:  
[mike.baledge@haileycityhall.org](mailto:mike.baledge@haileycityhall.org)*

## MEMO

**Date:** June 26, 2009  
**To:** Mariel Platt  
**From:** Mike Baledge  
**RE:** School District Fuel Tank

In regards to the planning commission's safety and environmental concerns, the school district has been working with me for several months to insure safety with this installation. The school district is installing a pre manufactured fuel storage vault. This is a quadruple walled tank with steel, Styrofoam, a leak shield liner and reinforced concrete. The manufacturing company and Underwriters Laboratories subject these tanks to abusive testing to insure safety and spill prevention. In addition to these safety features on the tank the school district is installing additional vehicle impact protection and fire extinguisher. This project, as planed meets all requirements of the International Fire Code and is acceptable to the fire department.