

*Hailey Fire Dept.
617 S. Third Street
P.O. Box 1192
Hailey, Idaho 83333*



*Capt. Michael Baledge
Fire Marshal
Office: 208-788-3147
Fax: 208-788-0279
E-mail:
mike.baledge@haileycityhall.org*

MEMO

Date: September 10, 2009
From: Mike Baledge
To: Mariel Platt
RE: School Tank Comments

Hi Mariel,

I have looked over the three alternative locations for the bio-diesel storage tank. All three sites comply with the fire code, as far as tank location. However, site 1 and 3 I believe are in the avalanche zone and will not accommodate the remote fueling station. Site 2 is the only site out of the avalanche zone that will accommodate the entire project.

I agree with the pros and cons that the school district provided and believe that the three new locations all have different risks associated with them like avalanche areas, proximity to the public, security risks, etc. It is still the position of the Fire Department that the site that was first proposed is still the safest and most appealing to the public.

Thank you, and if you have any questions please contact me.

Thank you,
Mike Baledge
Fire Marshal
City of Hailey