



PIPE LAYOUT SECTION

N.T.S.

NOTES

1. A No. 12 AWG copper with insulation tracer wire will be wrapped around all PVC pipe at a minimum of 10 foot intervals for the full length of the pipe. Each run shall be brought to the surface inside the Valve Boxes for the gate valves. Ten linear feet of loose looped wire shall be left coiled in the valve box. All runs shall be electrically continuous between valves.
2. All water pipe shall have 6 feet of minimum cover.
3. When Water and Sewer lines cross with less than (18") eighteen inches between pipes, refer to drawing 406.

REVISIONS

**2006 CITY OF HAILEY
IMPROVEMENT STANDARD
DRAWINGS**

WATER PIPE LAYING

405

DWG. NO.