



**NOTES**

- \* 1. ACTUAL DEPTH SHALL BE DETERMINED BY ENGINEER.
- 2. ACTUAL SIZE OF PERFORATED PIPE AND DRAIN AREA SHALL BE DESIGNED BY ENGINEER BASED ON PERCOLATION RATE OF SOIL TYPE & VOLUME OF WATER BEING DISCHARGED.
- 3. ALL SUBDIVIDERS AND APPLICANTS FOR COMMERCIAL OR INDUSTRIAL BUILDING PERMITS SHALL FURNISH DATA TO THE CITY WHICH SHOWS A DESIGN TO ACCOMMODATE THE RUN-OFF FROM A 1-HR, 25 YEAR STORM.

REVISIONS

**2006 CITY OF HAILEY  
IMPROVEMENT STANDARD  
DRAWINGS**

**TYPICAL DRY-WELL  
DRAINAGE CATCH BASIN**

**612**

**DWG. NO.**