

CITY OF HAILEY

POST CONSTRUCTION ELEVATION CERTIFICATE

Community No. 160022

2nd Survey:

I M P O R T A N T

This form must be completed and returned to the City of Hailey Building Department prior to obtaining a framing inspection.

SECTION I

The elevation certification must be completed by a registered professional engineer or surveyor.

Property Description: 1320 Aspen Valley Drive  
Subdivision Woodside Lot 9 Block 74 Plat 20  
FIA Map Panel on which property is located 160022-0001C  
FIA Map Zone in which property is located A0  
Base Flood Elevation at the proposed site 5310<sup>0</sup>  
Required minimum elevation of lowest floor 5311<sup>0</sup>  
NAME Woodside Rentals/Dick Fairfield DATE 6-18-86

ELEVATION CERTIFICATION

I certify that the building at the property location described above has the lowest floor at an elevation of 5310<sup>3</sup> feet, NGVD (mean Sea Level).

CERTIFIER'S NAME Bruce T. Butler  
TITLE City Engineer  
ADDRESS P.O. Box 478 Hailey, Idaho 83333  
SIGNATURE [Signature]  
DATE 6-18-86

AFFIX SEAL OR STAMP

