

CITY OF HAILEY

POST CONSTRUCTION ELEVATION CERTIFICATE

Community No. 160022

2nd Survey:

IMPORTANT

This form must be completed and returned to the City of Hailey Building Department prior to obtaining a framing inspection.

SECTION I

The elevation certification must be completed by a registered professional engineer or surveyor.

Property Description: 1351 Blue Lake Drive
Subdivision Woodside Lot 5 Block 73 Plat 19
FIA Map Panel on which property is located 160022-0001C
FIA Map Zone in which property is located A0
Base Flood Elevation at the proposed site 5306.0
Required minimum elevation of lowest floor 5307.0
NAME Patterson, James Peter DATE 6-18-86

ELEVATION CERTIFICATION

I certify that the building at the property location described above has the lowest floor at an elevation of 5306.7 feet, NGED (mean Sea Level).

CERTIFIER'S NAME Bruce T. Butler
TITLE City Engineer
ADDRESS P.O. Box 478 Hailey, Idaho 83333
SIGNATURE [Signature]
DATE 6-18-86

AFFIX SEAL OR STAMP

